Energy performance certificate (EPC)

FIRST FLOOR 53A BREWER STREET LONDON W1F 9UH Energy rating

Valid until: 2 August 2031

Certificate number:

7808-4653-6100-9733-5423

Property type

B1 Offices and Workshop businesses

Total floor area


69 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is D.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

22 A

If typical of the existing stock

66 C

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	66.7
Primary energy use (kWh/m2 per year)	395

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\frac{\text{recommendation report}}{(\text{/energy-certificate/4573-4206-1991-1148-6658})}$.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Mark Lewis
Telephone	02089311900
Email	markbenlewis@hotmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/010017
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer address 35 Meadow Gardens Edgware HA8 9LQ Assessor's declaration The assessor is not related to the owner of Date of assessment 2 August 2021	
Date of assessment 2 August 2021	f the property.
Date of certificate 3 August 2021	